



**Pxl Carpets**  
**Westerring 27j**  
**9700 Oudenaarde**

**Your message**

**Your reference**

**our reference**

**Gent**

Jw/544

2021-02-22

Comments on order A20.01261.01

---

Dear,

On the received carpet quality C1000 AB, our sample reference T2004676 we performed following tests:

- **Standard for the surface flammability of carpets and rugs according CFR 1630-FF 1-70**
- **Reaction to fire tests for floorings - Determination of the burning behaviour using a radiant heat source according ASTM E648 (2015)**

Based on the results we can mention that carpet quality C1000 AB is compliant with the criteria for the surface flammability and fulfils class I rating for fire behaviour specified in the National Fire Protection Association (NFPA).

We hope having been helpful with this information.

Yours sincerely,  
PhD. Jo Wynendaele  
Consultant Floor and Wall coverings