



**Pxl Carpets**  
**Westerring 27j**  
**9700 Oudenaarde**

**Your message**

**Your reference**

**our reference**

**Gent**

Jw/545

2021-02-22

Comments on order A20.01261.03

---

Dear,

On the received carpet quality C1100, our sample reference T2004677 we performed following tests:

- **Standard for the surface flammability of carpets and rugs according CFR 1630-FF 1-70**
- **Reaction to fire tests for floorings - Determination of the burning behaviour using a radiant heat source according ASTM E648 (2015)**

Based on the results we can mention that carpet quality C1100 is compliant with the criteria for the surface flammability and fulfils class I rating for fire behaviour specified in the National Fire Protection Association (NFPA) and fulfils criteria for B<sub>fl</sub>-s1 according EN 13501-1.

We hope having been helpful with this information.

A handwritten signature in blue ink, appearing to read 'J. Wynendaele', with a long horizontal stroke extending to the right.

Yours sincerely,  
PhD. Jo Wynendaele  
Consultant Floor and Wall coverings