



Pxl Carpets
Westerring 27j
9700 Oudenaarde

Your message

Your reference

our reference

Gent

Jw/547

2021-02-22

Comments on order A20.01261.06-.08

Dear,

On the received carpet quality C1700, our sample reference T2004679 we performed following tests:

- **Standard for the surface flammability of carpets and rugs according CFR 1630-FF 1-70**
- **Reaction to fire tests for floorings - Determination of the burning behaviour using a radiant heat source according ASTM E648 (2015)**

Based on the results we can mention that carpet quality C1700 is compliant with the criteria for the surface flammability and fulfils class I rating for fire behaviour specified in the National Fire Protection Association (NFPA) and fulfils criteria for B_{fl}-s1 according EN 13501-1.

We hope having been helpful with this information.

Yours sincerely,
PhD. Jo Wynendaele
Consultant Floor and Wall coverings